

Tillverkarens Prestandadeklaration
Enligt byggproduktförordningen EU nr 305/2011
Nummer: DoP X10/X10i 2410

1. Unik produktidentifikationskod:
X10
2. Typ, batch, serienummer eller något annat nummer som möjliggör identifiering av produkten enligt artikel 11.4:
Brandvarnare
X10 & X10i
3. Avsedd användning av byggprodukten i enlighet med tillämplig harmoniserad teknisk specifikation, enligt tillverkaren:
Branddetekterings- och brandlarmsanordning installerad i bostäder.
4. Namn, registrerat firmanamn eller registrerat varumärke och kontaktadress för den tillverkare som krävs enligt artikel 11.5:
Deltronic Security AB
EA Rosengrensgata 4
421 23 Västra Frölunda
Sweden
5. I tillämpliga fall, namn och kontaktadress till den auktoriserade representant vars uppdrag omfattar de uppgifter som anges i artikel 12.2:
Deltronic Security AB
EA Rosengrensgata 4
421 23 Västra Frölunda
Sweden
6. System för bedömning och fortlöpande kontroll av byggprodukt enligt bilaga V:
System1
- 7a. Byggprodukten omfattas av harmoniserad standard: **EN14604:2005/AC:2008**
Anmält organ: **BSI GRoup The Netherlands B.V, Notified Body no. 2797**
Som utfört typprovning, första inspektion av tillverkningsanläggningen och verifierat fabriken produktionskontroll med kontinuerlig övervakningsbedömning samt godkännande av fabriken produktionskontroll enligt system 1, vidare utfärdat följande EG-certifikat om överensstämmelse: **2797-CPR-809245**
- 7b. Byggprodukten omfattas av harmoniserad standard: **BS EN14604:2005/AC:2008**
Anmält organ: **BSI Assurance UK Limited, Notified Body no. 0086**
Som utfört typprovning, första inspektion av tillverkningsanläggningen och verifierat fabriken produktionskontroll med kontinuerlig övervakningsbedömning samt godkännande av fabriken produktionskontroll enligt system 1, vidare utfärdat följande UKCA-certifikat om överensstämmelse: **0086-CPR-809514**

8. När det gäller prestandadeklarationen avseende en byggprodukt för vilken en Europeisk teknisk utvärdering har utfärdats:
Inte tillämplig. Se punkt 7a & 7b.
9. Deklarerad prestanda:
Alla krav inklusive alla väsentliga egenskaper och motsvarande prestanda för den eller de avsedda användningarna som anges i punkt 3. har fastställts enligt beskrivningen i följande tabell:

Väsentliga egenskaper	Prestanda	Harmoniserad teknisk specifikation BS/EN14604:2005/AC:2008
Nominella aktiveringsförhållanden/ känslighet, svarsfördröjning (svarstid) och prestanda under brandtillstånd	Uppfyller	4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20
Driftsäkerhet	Uppfyller	4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 4.10, 4.11, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.23, 5.24
Tolerans mot matningsspänning	Uppfyller	5.21
Hållbarhet för driftsäkerhet och svars- fördröjning, temperaturbeständighet	Uppfyller	5.7, 5.8
Hållbarhet för driftsäkerhet, vibrationsmotstånd	Uppfyller	5.12, 5.13
Hållbarhet för driftsäkerhet, fuktbeständighet	Uppfyller	5.9
Hållbarhet för driftsäkerhet, korrosionsbeständighet	Uppfyller	5.10
Hållbarhet för driftsäkerhet, elektrisk stabilitet	Uppfyller	5.14

10. Prestanda för produkten som identifieras under punkt 1 och 2 överensstämmer med den deklarerade prestanda i punkt 9. Denna prestandadeklaration utfärdas på eget ansvar av tillverkaren som identifieras i punkt 4.

Signerad för och på uppdrag av tillverkaren av:

Mats Jonsson, Produktchef



Signatur
2024-10-09

Manufacturer Declaration of Performance
According to Construction Products Regulation EU No. 305/2011
Number: DoP X10/X10i 2410

1. Unique Product identification code::
X10
2. Type, batch, serial number or any other element allowing identification of the construction product as required by Article 11.4:
Smoke Alarm
X10 & X10i
3. Intended use of uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
Fire detection and fire alarm device installed in residential dwellings.
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11.5:
Deltronic Security AB
EA Rosengrens gata 4
421 23 Västra Frölunda
Sweden
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12.2:
Deltronic Security AB
EA Rosengrens gata 4
421 23 Västra Frölunda
Sweden
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
System1
- 7a. The construction product is covered by the harmonised standard: **EN14604:2005/AC:2008**
Notified body: **BSI GRoup The Netherlands B.V, Notified Body no. 2797**
Having carried out type testing, initial inspection of the manufacturing plant and verified the factory production control with continuous surveillance assessment and the approval of factory production control under system 1, further issued the following
EC certificate of conformity: 2797-CPR-809245
- 7b. The construction product is covered by the harmonised standard: **BS EN14604:2005/AC:2008**
Notified body: **BSI Assurance UK Limited, Notified Body no. 0086**
Having carried out type testing, initial inspection of the manufacturing plant and verified the factory production control with continuous surveillance assessment and the approval of factory production control under system 1, further issued the following
UKCA certificate of conformity: 0086-CPR-809514

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Not applicable. See item 7a & 7b.
9. Declared performance:
All requirements including all Essential Characteristics and the corresponding performance for the intended use or uses indicated in 3. have been determined as described in the following table.

Essential characteristics	Performance	Harmonized Technical Specification BS/EN 14604:2005/AC:2008
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire condition	Pass	4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20
Operational reliability	Pass	4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 4.10, 4.11, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.23, 5.24
Tolerance to supply voltage	Pass	5.21
Durability of operational reliability and response delay, temperature resistance	Pass	5.7, 5.8
Durability of operational reliability, vibration resistance	Pass	5.12, 5.13
Durability of operational reliability, humidity resistance	Pass	5.9
Durability of operational reliability, corrosion resistance	Pass	5.10
Durability of operational reliability, electrical stability	Pass	5.14

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of the manufacturer by:

Mats Jonsson, Product Manager


Signature
2024-10-09